

# Energy Savings Report




Reference

;

Prepared By: Richard Ellis

Version: 1.0

## Energy Consumption: Before and After



Reference

Energy Savings Report

8/18/2009

Zone #	Location	Existing KWH	Proposed KWH	KWH Savings	\$\$ Savings
<b>typical</b>					
1.00	Front Office Area Common	13,213.20	5,468.32	7,744.88	965.39
1.20	Front Office Area Offices	4,492.80	2,695.68	1,797.12	234.56
2.00	Warehouse	1,301.30	334.62	966.68	117.16
4.00	Manufacturing	49,860.10	21,086.21	28,773.89	3,513.71
5.00	Inspection Stations	7,687.68	2,525.95	5,161.73	632.30
6.00	Shipping & Receiving	11,331.84	4,592.64	6,739.20	823.91
7.00	Shipping Office	728.00	384.80	343.20	43.33
<b>typical</b>		<b>88,615</b>	<b>37,088</b>	<b>51,527</b>	<b>\$6,330</b>

**Grand Total:**

**88,615**

**37,088**

**51,527**

**\$ 6,330**

These savings are based on an average power rate of 0.1200 \$ per KWh and an average burn time as defined in the Building Usage Report.